

SPS 314 FIRE PREVENTION CODE COUNCIL

MEETING MINUTES

Tuesday, August 13, 2013

PRESENT: John Ashley, Todd Blaser, Gregg Cleveland, Tod Doebler, Jennie Macaluso-Ruditys, Brian McKee

STAFF: Jeff Weigand, Policy Director; Carl Frisque, Fire Prevention Coordinator; Brian Rausch, Engineering Consultant; and Sam Rockweiler, Rules Coordinator

Gregg Cleveland called the meeting to order at 9:00 a.m. A quorum of six members was present.

APPROVAL OF MINUTES

Amendments to the Minutes:

- None

MOTION: Tod Doebler moved, seconded by Todd Blaser, to approve the minutes of July 2, 2013, as published. Motion carried unanimously.

AGENDA ITEM: DISCUSS NFPA 1 FIRE CODETM TECHNICAL/SUBSTANTIVE CHANGES FROM THE 2009 EDITION TO THE 2012 EDITION

MOTION: Brian McKee moved, seconded by John Ashley, to recommend that the Department add the design requirements from chapter 36 of the 2012 edition of NFPA 1, relating to telecommunication facilities and information technology equipment, to chapters SPS 361 to 366, for commercial buildings. Motion failed.

MOTION: Brian McKee moved, seconded by John Ashley, to ask the Department to review – within 30 days – the design requirements in chapter 36 of the 2012 edition of NFPA 1, relating to telecommunication facilities and information technology equipment, for inclusion in chapters SPS 361 to 366, through either an emergency rule, a permanent rule, or a comprehensive update of the chapters, whichever is most expeditious. Motion carried, with one dissent.

MOTION: Tod Doebler moved, seconded by Jennie Macaluso-Ruditys, to ask the Department to review – within 30 days – the design requirements in NFPA 96, relating to ventilation control and fire protection of commercial cooking operations, for inclusion in chapters SPS 361 to 366, through either an emergency rule, a permanent rule, or a comprehensive update of the chapters, whichever is most expeditious. Motion carried, with one dissent.

MOTION: Tod Doebler moved, seconded by Brian McKee, to ask the Department to review – within 30 days – the design requirements in NFPA 1 sections 50.6.3 to 50.6.3.5, relating to storage systems for cooking oil, for inclusion in chapter SPS

310, and to relay the outcome of the review to the Department of Agriculture, Trade and Consumer Protection. Motion carried unanimously.

AGENDA ITEM: DISCUSS RADIO COVERAGE INSIDE BUILDINGS

MOTION: Tod Doeblner moved, seconded by John Ashley, to accept the new requirements in NFPA 1 sections 11.10.1 to 11.10.3, relating to two-way radio communication enhancement systems. Motion carried, with one dissent and one abstention.

ADJOURNMENT

MOTION: Brian McKee moved, seconded by Todd Blaser, to adjourn the meeting. Motion carried unanimously.

The meeting adjourned at 2:00 p.m.

File reference: SPS 314/Minutes 08.13